

**Addendum No. 2
to the
Plans And Specifications
for the
MMRC Speculative Building
MMRC Regional Business Park
MMRC Industrial Development Authority**

Bid Date: December 1, 2011

November 29, 2011

The Contractor shall conform to the following changes, as same shall become binding upon the Contract to be issued in response to this invitation.

Specifications

- Item 1:** Section 13120 - Pre-Engineered Metal Building System, page 13120-3 paragraph D. Additional Loads, delete mechanical roof top units.
- Item 2:** Section 13120 - Pre-Engineered Metal Building System, page 13120-3, paragraph F. Deflection Limits, change number 4, Girts from L/360 to L/240.

End of Addendum No. 2

MSE of Kentucky, Inc.