

**Addendum No. 3
to the
Plans And Specifications
for the
MMRC Speculative Building
MMRC Regional Business Park
MMRC Industrial Development Authority**

Bid Date: December 1, 2011

November 30, 2011

The Contractor shall conform to the following changes, as same shall become binding upon the Contract to be issued in response to this invitation.

Electrical

Item 1: Contractor shall provide three – 3” conduits for the primary side of the padmount transformer to the utility pole in lieu of one – 4” conduit.

End of Addendum No. 3

MSE of Kentucky, Inc.