

PANELBOARD SCHEDULE									
PANEL DESIGNATION		PANEL LOCATION		PANEL VOLTAGE		PANEL RATING		PANEL NUMBER	
AA		480/277 VOLT 3Ø 4W		225 AMP		14,000		1866	
Ckt No	TRIP/POLE	LOAD DESCRIPTION & LOCATION	LOAD (WATTS)			LOAD DESCRIPTION & LOCATION	Ckt Brkr	TRIP/POLE	NO
			AØ	BØ	CØ				
1	20/1	LIGHTING	2790			LIGHTING	20/1	2	2
3	20/1	LIGHTING	2790			LIGHTING	20/1	4	4
5	20/1	LIGHTING	2790			LIGHTING	20/1	6	6
7	20/1	LIGHTING	1695			LIGHTING	20/1	8	8
9	20/1	LIGHTING	3090			LIGHTING	20/1	10	10
11	20/1	LIGHTING	2790			LIGHTING	20/1	12	12
13	20/1	LIGHTING	2790			LIGHTING	20/1	14	14
15	20/1	LIGHTING	2775			LIGHTING	20/1	16	16
17	20/1	LIGHTING	2325			LIGHTING	20/1	18	18
19	20/1	LIGHTING	1595			LIGHTING	20/1	20	20
21	20/1	LIGHTING	2200			EXTERIOR FLOOD LIGHTING	20/1	22	22
23	20/1	LIGHTING	2625			EXTERIOR FLOOD LIGHTING	20/1	24	24
25	20/1	LIGHTING	3290			EXTERIOR FLOOD LIGHTING	20/1	26	26
27	20/1	LIGHTING	2790			EXTERIOR FLOOD LIGHTING	20/1	28	28
29	20/1	LIGHTING	2325			LIGHTING	20/1	30	30
31	20/1	LIGHTING	1860			LIGHTING	20/1	32	32
33	20/1	LIGHTING	2325			LIGHTING	20/1	34	34
35	15/1	EF-10	1385			LIGHTING	20/1	36	36
37	15/3	SF-3	1385			LIGHTING	20/1	38	38
39	15/1	EF-11	1385			LIGHTING	20/1	40	40
41	20/1	EFW-1	2000			LIGHTING	20/1	42	42
43	20/1	EFW-1	2000			LIGHTING	20/1	44	44
45	20/1	SPARE				LIGHTING	20/1	46	46
47	20/1	CHILLER ROOM EWH-1	2000			BASEMENT LIGHTING	20/1	48	48
49	20/1	SPARE				PARKING LOT LIGHTING	20/1	50	50
51	20/1	SPARE				PARKING LOT LIGHTING	20/1	52	52
53	20/1	SPARE				LIGHTING	20/1	54	54
55	20/1	SPARE				LIGHTING	20/1	56	56
57	20/1	SPARE				LIGHTING-PIT "B"	20/1	58	58
59	20/1	SPARE				LIGHTING-PIT "A"	20/1	60	60
61	20/1	DRYER TOWER LIGHTING	2484			LIGHTING-DRYER TOWER STAIRWELL	20/1	62	62
63	20/1	DRYER TOWER LIGHTING	2160			LIGHTING-DRYER TOWER STAIRWELL	20/1	64	64
65	-/1	SPARE				SPARE	20/1	66	66
67	-/1	SPARE				SPARE	20/1	68	68
69	-/1	SPARE				SPARE	20/1	70	70
71	-/1	SPARE				SPARE	20/1	72	72
73	-/1	SPARE				SPARE	20/1	74	74
75	-/1	SPARE				SPARE	20/1	76	76
77	-/1	SPARE				SPARE	20/1	78	78
79	-/1	SPARE				SPARE	20/1	80	80
81	-/1	SPARE				SPARE	20/1	82	82
83	-/1	SPARE				SPARE	20/1	84	84

PANELBOARD SCHEDULE									
PANEL DESIGNATION		PANEL LOCATION		PANEL VOLTAGE		PANEL RATING		PANEL NUMBER	
BB		480/277 VOLT 3Ø 4W		225 AMP		14,000		1866	
Ckt No	TRIP/POLE	LOAD DESCRIPTION & LOCATION	LOAD (WATTS)			LOAD DESCRIPTION & LOCATION	Ckt Brkr	TRIP/POLE	NO
			AØ	BØ	CØ				
1	20/1	LIGHTING	2500			EXTERIOR FLOOD LIGHTS	20/1	2	2
3	20/1	LIGHTING	3120			EXTERIOR FLOOD LIGHTS	20/1	4	4
5	20/1	LIGHTING	1200			EXTERIOR FLOOD LIGHTS	20/1	6	6
7	20/1	LIGHTING	2890			LIGHTING	20/1	8	8
9	20/1	LIGHTING	2790			LIGHTING	20/1	10	10
11	20/1	LIGHTING	2790			LIGHTING	20/1	12	12
13	20/1	LIGHTING	2790			LIGHTING	20/1	14	14
15	20/1	LIGHTING	2790			LIGHTING	20/1	16	16
17	20/1	LIGHTING	2790			LIGHTING	20/1	18	18
19	20/1	LIGHTING	3180			LIGHTING	20/1	20	20
21	20/1	LIGHTING	3455			LIGHTING	20/1	22	22
23	20/1	LIGHTING	2790			LIGHTING	20/1	24	24
25	20/1	LIGHTING	2890			LIGHTING	20/1	26	26
27	20/1	LIGHTING	3190			LIGHTING	20/1	28	28
29	20/1	LIGHTING	2790			LIGHTING	20/1	30	30
31	20/1	LIGHTING	2790			LIGHTING	20/1	32	32
33	20/1	LIGHTING	2790			LIGHTING	20/1	34	34
35	20/1	LIGHTING	2990			LIGHTING	20/1	36	36
37	20/1	LIGHTING	3600			LIGHTING	20/1	38	38
39	20/1	LIGHTING	2990			LIGHTING	20/1	40	40
41	20/1	EFW-1	2000			EFW-1	20/1	42	42
43	20/1	EFW-1	2000			EFW-1	20/1	44	44
45	20/1	EFW-1	2000			EFW-1	20/1	46	46
47	20/1	SPARE				SPARE	20/1	48	48
49	20/1	SPARE				SPARE	20/1	50	50
51	20/1	SPARE				SPARE	20/1	52	52
53	20/1	SPARE				SPARE	20/1	54	54
55	20/1	SPARE				SPARE	20/1	56	56
57	20/1	SPARE				SPARE	20/1	58	58
59	20/1	SPARE				SPARE	20/1	60	60
61	20/1	SPARE				SPARE	20/1	62	62
63	20/1	SPARE				SPARE	20/1	64	64
65	20/1	SPARE				SPARE	20/1	66	66
67	20/1	SPARE				SPARE	20/1	68	68
69	20/1	SPARE				SPARE	20/1	70	70
71	20/1	SPARE				SPARE	20/1	72	72
73	20/1	SPARE				SPARE	20/1	74	74
75	20/1	SPARE				SPARE	20/1	76	76
77	20/1	SPARE				SPARE	20/1	78	78
79	20/1	SPARE				SPARE	20/1	80	80
81	20/1	SPARE				SPARE	20/1	82	82
83	20/1	SPARE				SPARE	20/1	84	84

PANELBOARD SCHEDULE									
PANEL DESIGNATION		PANEL LOCATION		PANEL VOLTAGE		PANEL RATING		PANEL NUMBER	
DD		277/480 VOLT 3Ø 4W		400 AMP		14,000		1866	
Ckt No	TRIP/POLE	LOAD DESCRIPTION & LOCATION	LOAD (W/PHASE)			LOAD DESCRIPTION & LOCATION	Ckt Brkr	TRIP/POLE	NO
			AØ	BØ	CØ				
1	20/1	LIGHTING	2400			LIGHTING	20/1	2	2
3	20/1	LIGHTING	2407			LIGHTING	20/1	4	4
5	20/1	LIGHTING	2250			LIGHTING	20/1	6	6
7	20/1	LIGHTING	1024			LIGHTING	20/1	8	8
9	20/1	LIGHTING	1024			HPU-2 [RTU-2]	40/3	10	10
11	50/3	HPU-1 [RTU-1]	11,897					12	12
13			11,897					14	14
15			11,897			HPU-3 [RTU-3]	60/3	16	16
17	50/3	HPU-4 [RTU-4]	16,877					18	18
19			16,877					20	20
21	20/3	ERV-1	16,877			HPU-5 [RTU-5]	50/3	22	22
23			3292					24	24
25			3292					26	26
27			16,877					28	28
29	20/1	SPARE				SIGN LIGHTING	20/1	30	30
31	20/1	SPARE				SPARE	20/1	32	32
33	20/1	SPARE				SPARE	20/1	34	34
35	20/1	SPARE				SPARE	20/1	36	36
37	20/1	SPARE				SPARE	20/1	38	38
39	20/1	SPARE				SPARE	20/1	40	40
41	20/1	SPARE				SPARE	20/1	42	42

PANELBOARD SCHEDULE									
PANEL DESIGNATION		PANEL LOCATION		PANEL VOLTAGE		PANEL RATING		PANEL NUMBER	
M1		277/480 VOLT 3Ø 4W		400 AMP		14,000		1866	
Ckt No	TRIP/POLE	LOAD DESCRIPTION & LOCATION	LOAD (W/PHASE)			LOAD DESCRIPTION & LOCATION	Ckt Brkr	TRIP/POLE	NO
			AØ	BØ	CØ				
1	45/3	RTU-25	9695			RTU-18	80/3	2	2
3			9695					4	4
5			9695					6	6
7			9695					8	8
9			9695					10	10
11	80/3	RTU-19	18282			RTU-20	80/3	12	12
13			18282					14	14
15			18282					16	16
17	80/3	RTU-21	18282			EF-7	15/3	18	18
19			18282					20	20
21			18282					22	22
23			1329					24	24
25			1329					26	26
27								28	28
29								30	30

PANELBOARD SCHEDULE									
PANEL DESIGNATION		PANEL LOCATION		PANEL VOLTAGE		PANEL RATING		PANEL NUMBER	
M3		480/277 VOLT 3Ø 4W		250 AMP		14,000		1866	
Ckt No	TRIP/POLE	LOAD DESCRIPTION & LOCATION	LOAD (W/PHASE)			LOAD DESCRIPTION & LOCATION	Ckt Brkr	TRIP/POLE	NO
			AØ	BØ	CØ				
1	15/3	EF-1	830			EF-1	15/3	2	2
3			830					4	4
5			830					6	6
7	15/3	EF-1	830			EF-1	15/3	8	8
9			830					10	10
11			830					12	12
13	20/3	GUH-1	400			RTU-23	45/		