



Addendum No. 1
Water And Sewer Extensions
City Of Corbin Hotel Site
Corbin, KY
Bid Date: October 24, 2023
Issue Date: October 16, 2023

Bid Schedule
Part 1 - Water Line work

Bid Item #4A

The water line connections for the water main by-pass shall be made without interruption to service through the existing main until the by-pass is complete, tested, chlorinated and in service. Contractor shall utilize hot taps and line stops as necessary for the tie-ins. Bid item number 4A is hereby addended to include line stops, hot taps and any other equipment and materials for the complete tie-in to provide uninterrupted water supply service.

- End of Addendum -