



MSE of Kentucky, Inc.

Engineers/Architects/Planners

624 Wellington Way
Lexington,
Kentucky 40503
859-223-5694
FAX 859-223-2607
E-Mail: mseinc@mselex.com

Addendum No. 2
London-Laurel County Economic Development Authority
Lily Industrial Park Water, Sewer and Gas Line Extensions to the Greta Lane Spec Building
Bid Date: July 24, 2025
Addendum Issue Date: July 16, 2025

The Contractor shall conform to the following changes, as same shall become binding upon the Contract to be issued in response to this invitation.

Specifications

TABLE OF CONTENTS – There is no Section 11220 Submersible Sewage Pump Station in the project as listed on the TOC.

BID SCHEDULE – PART 1 WATER LINE WORK

Bid Item No. 1

The water main shall be 8” diameter as shown in the plans and not 12” as stated in the bid form.

Bid Item No. 5

The tie in to the existing main by tapping valve and sleeve will be completed by the Laurel County Water District No. 2 and it will be paid directly to them by the London-Laurel County Economic Development Authority. This bid item therefore does not include the tap, tapping valve and sleeve but rather includes simply connecting the new main to the provided tap. This item also includes the connection at the building plumbing piping as shown. This item also hereby includes the complete fire vault and the backflow preventers vaults including the vaults, lids, meters, valves, piping etc. as shown in the plans.

BID SCHEDULE – PART 2 SEWER LINE WORK

Bid Item No. 3

This item is not for a force main as stated. The casing pipe shall be bored to grade under Greta Lane and sized to accommodate the new 8” gravity main.

END OF ADDENDUM NO. 2